


REVISIONS				
ZONE	REV.	DESCRIPTION	DATE	APPROVED

ONE SSG MOUNTING HOLE PER SIDE LINES UP WITH THE EXISTING MOUNTING BRACKET HOLES. TWO 8-32 SCREWS SHOULD BE ABLE TO KEEP THIS UNIT FROM SLIDING OUT OF THE MOUNTING BRACKET. THE EXISTING MOUNTING BRACKET HOLES MAY HAVE TO BE ENLARGED .020, IT'S CLOSE.



SSG 1.5K RM MOUNTING HOLE PATTERN

		FED. NO.		PART OR IDENTIFYING NO.		NOMENCLATURE OR DESCRIPTION		MATERIAL SPECIFICATION		QTY REQD.	
						PARTS LIST					
						APPROVALS		DATE		FALCON ELECTRIC INC.	
						MANAGEMENT				5116 AZUSA CANYON RD. IRVINDALE, CA.	
						DRAWN				SSG1.5KRM VERTICAL MTG BRKT	
						CHECKED					
						RESP ENG					
						MFG ENG					
						QUAL ENG				SHEET 1 OF 1	
						DO NOT SCALE DRAWING					